

AFFAIRS (PERA)

MIAMI-DADE COUNTY PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208 Miami, Florida 33175-2474 T (786)315-2590 F (786) 31525-99 www.miamidade.gov/pera

BOARD AND CODE ADMINISTRATION DIVISION NOTICE OF ACCEPTANCE (NOA)

GenFlex Roofing Systems A Division of Firestone Building Products Company, LLC 250 West 96th Street Indianapolis, IN 46260

DEPARTMENT OF PERMITTING, ENVIRONMENT, AND REGULATORY

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County PERA - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. PERA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: TPO Single Ply Roof Systems over Concrete Deck.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 06-1010.11 and consists of pages 1 through 35. The submitted documentation was reviewed by Jorge L. Acebo.



Ander

NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12 Page 1 of 35

ROOFING SYSTEM APPROVAL

Category: Roofing

Sub-Category: Single Ply Roofing

Material:TPODeck Type:ConcreteMaximum Design Pressure:-232.5 psf

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT: TABLE 1

Test Product Name Dimensions Specifications Product Description GenFlex TPO 45", 75", 96", 120" or **TAS 131** Polyester reinforced Thermo Plastic 148" wide x 100' long x ASTM D 6878 Olefin single ply membrane. 45 or 60 mils thick GenFlex TPO Plus 48" or 96" wide by 100' **TAS 131** Polyester reinforced Thermo Plastic long x 70 or 80 mils thick ASTM D 6878 Olefin single ply membrane. Polyester reinforced Thermo Plastic GenFlex TPO Peel 18.75", 37.5", 75", 120" **TAS 131** & Stick HW wide x 100' long x 45 or ASTM D 6878 Olefin single ply membrane with a self-60 mils thick adhered backing and heat weld laps. GenFlex TPO Peel 18.75", 37.5", 75" wide x **TAS 131** Fiberglass scrim reinforced Thermo & Stick SA 100' long x 45 or 60 mils ASTM D 6878 Plastic Olefin single ply membrane thick with a self-adhered backing, and self-

Proprietary

TARLE 2

adhering laps.

Solvent based, contact adhesives for

bonding of roof membrane to substrate.

APPROVED INSULATIONS:

5 gallon pails

GenFlex TPO

Bonding Adhesive

	I ABLE 2	
Product	Product Description	Manufacturer
		(With current NOA)
ACFoam II, ACFoam III	Isocyanurate insulation	Atlas Roofing Corp.
ACFoam composite	Isocyanurate insulation with perlite facer	Atlas Roofing Corp.
ENRGY 3, ENRGY 3 Plus	Isocyanurate insulation with wood	Johns Manville
	fiberboard facer	
Multi-Max FA-3	Isocyanurate insulation	R-Max, Inc
Thermaroof Composite-3	Isocyanurate insulation with perlite facer	R-Max, Inc
Structodek High Density	Wood fiberboard insulation	Blue Ridge Fiberboard,
Fiberboard Roof Insulation		Inc.
DensDeck, DensDeck Prime	Silicon treated gypsum	G-P Products
H-Shield	Isocyanurate insulation	Hunter Panels, LLC.
ISO 95+ GL	Isocyanurate insulation	Firestone Building
		Products
GenFlex ISO 3	Polyisocyanurate foam core insulation	GenFlex Roofing
		Systems
XPS	Type IV Extruded polystyrene with a	Generic
	minimum density of 1.6 pcf	
EPS	Type IX Expanded polystyrene with a	Generic
	minimum density of 1.8 pcf	
High Density Fiberboard	Wood fiberboard insulation	Generic



NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12 Page 2 of 35

APPROVED FASTENERS:

TABLE 3			
	Product	Product Description	Manufacturer
		_	(With current NOA)
1.	GenFast Polymer Batten Strip	Batten Bar	GenFlex Roofing Systems
2.	GenFast #15 (WH) Fastener	Insulation and membrane fasteners	GenFlex Roofing Systems
3.	GenFast #14 Fastener	Insulation and membrane fasteners	GenFlex Roofing Systems
4.	GenFast 3" Round	Stress Plates	GenFlex Roofing Systems
	Insulation Plate		
5.	GenFlex Metal Anchor Bar	Batten Bar	GenFlex Roofing Systems
6.	Dekfast 14	Insulation and membrane fasteners	SFS Intec, Inc.
7.	Dekfast 15 HS &	Insulation and membrane fasteners	SFS Intec, Inc.
	Dekfast 15 Belted		
8.	#14 Roofgrip	Insulation and membrane fasteners	OMG, Inc.
9.	#15 Roofgrip	Insulation and membrane fasteners	OMG, Inc.
10.	#15 SPM Screw	Insulation and membrane fasteners	OMG, Inc.
11.	OMG Heavy Duty Screw	Insulation and membrane fasteners	OMG, Inc.
12.	OMG XHD Screw	Insulation and membrane fasteners	OMG, Inc.
13.	OMG 3" Round Metal Plates	Stress Plate	OMG, Inc.
14.	TruFast HD (#14) Fastener	Insulation and membrane fasteners	Tru-Fast Corp.
15.	TruFast SS HD (#14) Fastener	Insulation and membrane fasteners	Tru-Fast Corp.

EVIDENCE SUBMITTED:

Test Agency	Test Identifier	Description	Date
Factory Mutual Research	3009797	FM 4470	02/04/02
	3007119	FM 4470	01/02/02
	3005794	FM 4470	12/13/01
	3002357	FM 4470	05/16/00
	3005415	FM 4470	02/08/00
	3002775	FM 4470	09/16/99
	3000919	FM 4470	04/07/99
	3003690	FM 4470	03/29/99
	3B9A2.AM	FM 4470	01/25/99
	4B1A9.AM	FM 4470	09/09/98
	1D9A7.AM	FM 4470	07/31/98
	1D9A0.AM	FM 4470	07/30/98
	1D0A3.AM	FM 4470	09/24/97
	1B0A9.AM	FM 4470	05/09/97
	3015927	FM 4470	01/26/04
	3023988	FM 4470	09/29/05
	3025484	FM 4470	05/31/06
	3027476	FM 4470	08/11/06
Exterior Research & Design, LLC.	8054.02.02-1	TAS 131	02/22/02
Momentum Technologies, Inc.	EX30M3B	ASTM D 6878	06/17/04
Underwriters Laboratories, Inc.	01NK14490	Fire Classification	06/01/01
	96NK22037	TAS 114, (UL 790)	03/10/97
	01NK25823	TAS 114, (UL 1897)	07/02/01
Trinity ERD	F8300.09.09-2-R1	ASTM D6878	11/24/08



NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12

Page 3 of 35



APPROVED ASSEMBLIES:

Membrane Type: Single Ply, TPO

Deck Type 3I: Concrete, Insulated

Deck Description: Min. 2500 psi structural concrete

System Type A(1): One or more layers of insulation adhered to deck with approved asphalt or

adhesive.

All General and System Limitations apply.

Insulation Optional base layer(s) of maximum 4 x 4 ft (1.2 x 1.2 m) GenFlex ISO 3 or

Option #1: ACFoam II adhered to the deck or to each other with GenFlex One-Step

Insulation Adhesive applied in approximate 0.75 in. (19 mm) wide ribbons spaced 12 in (305 mm). One layer of maximum 4x4 ft (1.2 x 1.2 m) ENRGY 3 Plus adhered to the deck or to the base insulation layer with GenFlex One-Step Insulation Adhesive applied in approximate 0.75 in (19 mm) wide ribbons spaced

12 in (305 mm). Membrane applied as noted below.

Maximum Design Pressure: -45 psf

Insulation One or more layers of maximum 4 x 4 ft (1.2 x 1.2 m) GenFlex ISO 3 or ACFoam

Option #2: II adhered to the deck or to each other with GenFlex One-Step Insulation

Adhesive applied approximate 0.75 in (19 mm) wide ribbons spaced 12 in (305

mm). Membrane applied as noted below.

Maximum Design Pressure: -75 psf

Insulation Concrete deck shall be primed with ASTM D41 asphalt primer and allowed to

Option #3: dry. One or more layer of maximum 4 x 4 ft (1.2 x 1.2 m) GenFlex ISO 3 or

ACFoam II adhered to the deck or to each other with hot asphalt applied within the EVT range and at a rate of 20-40 lbs/ 100 ft². Membrane applied as noted

below

Maximum Design Pressure: -112.5 psf

Membrane: GenFlex TPO or GenFlex TPO Plus adhered to insulation using GenFlex TPO

Bonding Adhesive applied at 30 ft²/gal (0.7 m²/L) to both the substrate and the

bottom side of the roof cover for a combined rate of 60 ft²/gal (1.5 m²/L).

Maximum Design

Pressure: See insulation options above (See General Limitation #9)



NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12

Page 4 of 35

Deck Type 3I: Concrete, Insulated

Deck Description: Min. 2500 psi structural concrete or concrete plank

System Type A(2): One or more layers of insulation adhered to deck with approved asphalt or

adhesive, membrane fully adhered

All General and System Limitations apply.

<u>Insulation Base Layer</u> <u>Fastener Density ft²</u> <u>Fastener Type</u>

GenFlex ISO 3

Minimum: 1.0" thick N/A N/A

<u>Insulation Top Layer (Optional)</u> <u>Fastener Density ft²</u> <u>Fastener Type</u>

GenFlex ISO 3

Minimum: 1.0" thick N/A N/A

Note: All layers of insulation shall be adhered with approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.

Membrane: GenFlex TPO Peel & Stick HW, self-adhered to insulation with 3" wide laps

sealed with a minimum 1.5" wide heat weld or primed with GenFlex Clear Primer

and sealed with GenFlex 3" White TPO Seam Tape

Or

GenFlex TPO Peel & Stick SA, self-adhered to insulation with minimum 3" wide

laps. Laps are primed with GenFlex Clear Primer and hand rolled.

Maximum Design

Pressure: -45 psf; (See General Limitation #9)



NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12 Page 5 of 35

Deck Type 3I: Concrete, Insulated

Deck Description: Min. 2500 psi structural concrete or concrete plank

System Type A(3): One or more layers of insulation adhered to deck with approved asphalt or

adhesive, membrane fully adhered

All General and System Limitations apply.

<u>Insulation Base Layer</u> <u>Fastener Density ft²</u> <u>Fastener Type</u>

GenFlex ISO 3

Minimum: 1.0" thick N/A N/A

<u>Insulation Top Layer (Optional)</u> <u>Fastener Density ft²</u> <u>Fastener Type</u>

GenFlex ISO 3

Minimum: 1.0" thick N/A N/A

Note: All insulation shall be adhered to the deck and subsequent layers of insulation in GenFlex One-Step Insulation Adhesive in 0.75" wide ribbons spaced 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: GenFlex TPO Peel & Stick HW, self-adhered to insulation with 3" wide laps

sealed with a minimum 1.5" wide heat weld or primed with GenFlex Clear Primer

and sealed with GenFlex 3" White TPO Seam Tape

Or

GenFlex TPO Peel & Stick SA, self-adhered to insulation with minimum 3" wide

laps. Laps are primed with GenFlex Clear Primer and hand rolled.

Maximum Design

Pressure: -45 psf; (See General Limitation #9)

MIAMI-DADE COUNTY
APPROVED

NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12 Page 6 of 35

Deck Type 3I: Concrete, Insulated

Deck Description: Min. 2500 psi structural concrete

System Type A(4): One or more layers of insulation adhered to deck with approved asphalt or

adhesive.

All General and System Limitations apply.

One or more layers of the following:

Insulation Layer	Fastener Density ft ²	Fastener Type
GenFlex ISO 3, ACFoam II		
Minimum: 1.5" thick	N/A	N/A
DensDeck, DensDeck Prime)	
Minimum: 0.25" thick	N/A	N/A
Approved High Density Fib	erboard	

N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of base sheet. All insulation shall be adhered to the deck in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing

Application Standard RAS 117 for insulation attachment.

Membrane: GenFlex TPO or GenFlex TPO Plus adhered to insulation using GenFlex TPO

Bonding Adhesive applied to both the substrate and the bottom side of the roof

N/A

cover for a combined rate of 65 ft²/gal (1.6 m²/L)

Maximum Design

Minimum: 0.5" thick

Pressure: -202.5 psf (See General Limitation #9)



NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12 Page 7 of 35

Deck Type 3I: Concrete, Insulated

Deck Description: Min. 2500 psi structural concrete

System Type A(5): One or more layers of insulation adhered to deck with approved asphalt or

adhesive.

All General and System Limitations apply.

One or more layers of the following:

<u>Insulation Layer</u> Fastener Density ft² Fastener Type

ACFoam III

Minimum: 2.0" thick N/A

Note: All insulation shall be adhered to the deck or subsequent layers of insulation in Millennium One Step Foamable Adhesive in 0.75" wide beads spaced 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: GenFlex TPO Peel & Stick HW, self-adhered to insulation with 3" wide laps

sealed with a minimum 1.5" wide heat weld or primed with GenFlex Clear Primer

and sealed with GenFlex 3" White TPO Seam Tape

Or

GenFlex TPO Peel & Stick SA, self-adhered to insulation with minimum 3" wide

laps. Laps are primed with GenFlex Clear Primer and hand rolled.

Maximum Design

Pressure: -232.5 psf (See General Limitation #9)

MIAMI-DADE COUNTY
APPROVED

NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12 Page 8 of 35

Deck Type 3I: Concrete, Insulated

Deck Description: Min. 2500 psi structural concrete

System Type A(6): One or more layers of insulation adhered to deck with approved asphalt or

adhesive.

All General and System Limitations apply.

One or more layers of the following:

<u>Insulation Layer</u> <u>Fastener Density ft²</u> <u>Fastener Type</u>

GenFlex ISO 3, ACFoam II, ENRGY 3

Minimum: 1.5" thick N/A

DensDeck, DensDeck Prime

Minimum 0.25" thick N/A

Note: All insulation shall be adhered to the deck or subsequent layers of insulation in Millennium One Step Foamable Adhesive in 0.75" wide beads spaced 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: GenFlex TPO Peel & Stick HW, self-adhered to insulation with 3" wide laps

sealed with a minimum 1.5" wide heat weld or primed with GenFlex Clear Primer

and sealed with GenFlex 3" White TPO Seam Tape

Or

GenFlex TPO Peel & Stick SA, self-adhered to insulation with minimum 3" wide

laps. Laps are primed with GenFlex Clear Primer and hand rolled.

Maximum Design

Pressure: -165 psf (See General Limitation #9)



NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12 Page 9 of 35

Deck Type 3I: Concrete, Insulated

Deck Description: Min. 2500 psi structural concrete or concrete plank

System Type A(7): One or more layers of insulation adhered with approved <u>adhesive</u>, membrane

fully adhered

All General and System Limitations apply.

One or more layers of the following insulations:

Base Insulation Layer	Fastener Density/ft ²	Fastener Type
ACFoam II, H-Shield, ENRGY 3 Minimum 1.0" thick	N/A	N/A
DensDeck, DensDeck Prime Minimum 0.25" thick	N/A	N/A
Top Insulation Layer	Fastener Density/ft ²	Fastener Type
DensDeck, DensDeck Prime Minimum 0.25" thick	N/A	N/A

Note: All insulation shall be adhered to the deck in full coating of OlyBond Adhesive Fastener at a rate of 1 gal/sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: GenFlex TPO or GenFlex TPO Plus, adhered to insulation using GenFlex TPO

Bonding Adhesive applied to both the substrate and the bottom side of the roof

cover for a combined rate of 65 ft²/gal (1.6 m²/L)

Maximum Design

Pressure: -202.5 psf (See General Limitation #9)



NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12 Page 10 of 35

Deck Type 3I: Concrete, Insulated

Deck Description: Min. 2500 psi structural concrete or concrete plank

System Type A(8): One or more layers of insulation adhered with approved <u>adhesive</u>, membrane

fully adhered

All General and System Limitations apply.

One or more layers of the following insulations:

Base Insulation Layer (Optional)	Fastener Density/ft ²	Fastener Type
Approved EPS Insulation Boards Minimum 2.0" thick	N/A	N/A
Top Insulation Layer	Fastener Density/ft ²	Fastener Type
Structodek High Density Fiberboard Roof Insulation Minimum 1.0" thick	N/A	N/A
DensDeck, DensDeck Prime Minimum 0.25" thick	N/A	N/A

Note: All insulation shall be adhered to the deck in ¾" – 1" wide beads 12" o.c. of OlyBond 500 or OlyBond 500 Spot Shot Adhesive Fastener. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: GenFlex TPO or GenFlex TPO Plus, adhered to insulation using GenFlex TPO

Bonding Adhesive applied to both the substrate and the bottom side of the roof

cover for a combined rate of 65 ft²/gal (1.6 m²/L)

Maximum Design

Pressure: -120 psf (See General Limitation #9)



NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12

Page 11 of 35

Deck Type 3I: Concrete, Insulated

Deck Description: Min. 2500 psi structural concrete or concrete plank

System Type A(9): One or more layers of insulation adhered with approved <u>adhesive</u>, membrane

fully adhered

All General and System Limitations apply.

One or more layers of the following insulations:

<u>Insulation Layer</u> <u>Fastener Density/ft²</u> <u>Fastener Type</u>

ACFoam II, H-Shield, ISO 95+GL

Minimum 1.5" thick N/A N/A

Note: All insulation shall be adhered to the deck in ¾" – 1" wide beads 12" o.c. of OlyBond 500 or OlyBond 500 Spot Shot Adhesive Fastener. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: GenFlex TPO or GenFlex TPO Plus, adhered to insulation using GenFlex TPO

Bonding Adhesive applied to both the substrate and the bottom side of the roof

cover for a combined rate of 65 ft²/gal (1.6 m²/L)

Maximum Design

Pressure:

-150 psf (See General Limitation #9)



NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12 Page 12 of 35

Deck Type 3I: Concrete, Insulated

Deck Description: Min. 2500 psi structural concrete or concrete plank

System Type A(10): One or more layers of insulation adhered with approved <u>adhesive</u>, membrane

fully adhered

All General and System Limitations apply.

One or more layers of the following insulations:

<u>Base Insulation Layer (Optional)</u> <u>Fastener Density/ft²</u> <u>Fastener Type</u>

ACFoam II, H-Shield, ISO 95+GL

Minimum 1.5" thick N/A N/A

Top Insulation Layer Fastener Density/ft² Fastener Type

DensDeck, DensDeck Prime

Minimum 0.25" thick N/A N/A

Note: All insulation shall be adhered to the deck in ¾" – 1" wide beads 12" o.c. of OlyBond 500 or OlyBond 500 Spot Shot Adhesive Fastener. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: GenFlex TPO or GenFlex TPO Plus, adhered to insulation using GenFlex TPO

Bonding Adhesive applied to both the substrate and the bottom side of the roof

cover for a combined rate of 65 ft²/gal (1.6 m²/L)

Maximum Design

Pressure: -150 psf (See General Limitation #9)

MIAMI-DADE COUNTY
APPROVED

NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12

Page 13 of 35

Deck Type 3I: Concrete, Insulated

Deck Description: Min. 2500 psi structural concrete or concrete plank

System Type A(11): One or more layers of insulation adhered with approved <u>adhesive</u>, membrane

fully adhered

All General and System Limitations apply.

One or more layers of the following insulations:

Base Insulation Layer Fastener Density/ft² Fastener Type

ENRGY 3

Minimum 1.5" thick N/A N/A

Top Insulation Layer Fastener Density/ft² Fastener Type

DensDeck, DensDeck Prime

Minimum 0.25" thick N/A N/A

Note: All insulation shall be adhered to the deck in ¾" – 1" wide beads 12" o.c. of OlyBond 500 or OlyBond 500 Spot Shot Adhesive Fastener. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: GenFlex TPO or GenFlex TPO Plus, adhered to insulation using GenFlex TPO

Bonding Adhesive applied to both the substrate and the bottom side of the roof

cover for a combined rate of 65 ft²/gal (1.6 m²/L)

Maximum Design

Pressure: -127.5 psf (See General Limitation #9)

MIAMI-DADE COUNTY
APPROVED

NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12 Page 14 of 35

Deck Type 3I: Concrete, Insulated

Deck Description: Min. 2500 psi structural concrete or concrete plank

System Type A(12): One or more layers of insulation adhered with approved <u>adhesive</u>, membrane

fully adhered

All General and System Limitations apply.

One or more layers of the following insulations:

Base Insulation Layer Fastener Density/ft² Fastener Type

ISO 95+ GL

Minimum 1.5" thick N/A N/A

Top Insulation Layer Fastener Density/ft² Fastener Type

Structodek High Density Fiberboard Roof Insulation

Minimum 0.5" thick N/A N/A

Note: All insulation shall be adhered to the deck in ¾" – 1" wide beads 12" o.c. of OlyBond 500 or OlyBond 500 Spot Shot Adhesive Fastener. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: GenFlex TPO or GenFlex TPO Plus, adhered to insulation using GenFlex TPO

Bonding Adhesive applied to both the substrate and the bottom side of the roof

cover for a combined rate of 65 ft²/gal (1.6 m²/L)

Maximum Design

Pressure: -202.5 psf (See General Limitation #9)

MIAMI-DADE COUNTY
APPROVED

NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12 Page 15 of 35

Deck Type 3I: Concrete, Insulated

Deck Description: Min. 2500 psi structural concrete or concrete plank

System Type A(13): One or more layers of insulation adhered with approved <u>adhesive</u>, membrane

fully adhered

All General and System Limitations apply.

One or more layers of the following insulations:

Base Insulation Layer Fastener Density/ft² Fastener Type

Approved XPS Insulation Boards

Minimum 1.0" thick N/A N/A

Top Insulation Layer Fastener Density/ft² Fastener Type

DensDeck, DensDeck Prime

Minimum 0.25" thick N/A N/A

Note: All insulation shall be adhered to the deck in ¾" – 1" wide beads 12" o.c. of OlyBond 500 or OlyBond 500 Spot Shot Adhesive Fastener. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: GenFlex TPO or GenFlex TPO Plus, adhered to insulation using GenFlex TPO

Bonding Adhesive applied to both the substrate and the bottom side of the roof

cover for a combined rate of 65 ft²/gal (1.6 m²/L)

Maximum Design

Pressure: -202.5 psf (See General Limitation #9)

MIAMI-DADE COUNTY
APPROVED

NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12

Page 16 of 35

Deck Type 3I: Concrete, Insulated

Deck Description: Min. 2500 psi structural concrete or concrete plank

System Type A(14): One or more layers of insulation adhered with approved <u>adhesive</u>, membrane

fully adhered

All General and System Limitations apply.

One or more layers of the following insulations:

Insulation LayerInsulation Fasteners
(Table 3)Fastener
Density/ft²ACFoam II, ENRGY 3N/AN/AMinimum 1.5" thickN/AN/A

Note: All insulation shall be adhered to the deck in ½" to ¾" wide beads 12" o.c. of Millennium One Step Foamable Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: GenFlex TPO or GenFlex TPO Plus, adhered to insulation using GenFlex TPO

Bonding Adhesive applied to both the substrate and the bottom side of the roof

cover for a combined rate of 65 ft²/gal (1.6 m²/L)

Maximum Design

Pressure: -135 psf (See General Limitation #9)

MIAMI-DADE COUNTY
APPROVED

NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12

Page 17 of 35

Deck Type 3I: Concrete, Insulated

Deck Description: Min. 2500 psi structural concrete or concrete plank

System Type A(15): One or more layers of insulation adhered with approved <u>adhesive</u>, membrane

fully adhered

All General and System Limitations apply.

One or more layers of the following insulations:

Base Insulation Layer	<u>Insulation Fasteners</u> (Table 3)	<u>Fastener</u> Density/ft ²
ACFoam II, ENRGY 3		
Minimum 1.5" thick	N/A	N/A
Top Insulation Layer	<u>Insulation Fasteners</u> (Table 3)	<u>Fastener</u> Density/ft ²
DensDeck, DensDeck Prime	<u> </u>	
Minimum 0.25" thick	N/A	N/A

Note: All insulation shall be adhered to the deck in ½" to ¾" wide beads 12" o.c. of Millennium One Step Foamable Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: GenFlex TPO or GenFlex TPO Plus, adhered to insulation using GenFlex TPO

Bonding Adhesive applied to both the substrate and the bottom side of the roof

cover for a combined rate of 65 ft²/gal (1.6 m²/L)

Maximum Design

Pressure:

-75 psf (See General Limitation #9)



NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12

Page 18 of 35

Deck Type 3I: Concrete, Insulated

Deck Description: Min. 2500 psi structural concrete or concrete plank

System Type A(16): One or more layers of insulation adhered with approved <u>adhesive</u>, membrane

fully adhered

All General and System Limitations apply.

One or more layers of the following insulations:

Insulation LayerInsulation Fasteners
(Table 3)Fastener
Density/ft²ENRGY 3N/AN/AMinimum 1.5" thickN/AN/A

Note: All insulation shall be adhered to the deck in full coverage of Millennium One Step Foamable Adhesive at a rate of 1 gal/sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: GenFlex TPO or GenFlex TPO Plus, adhered to insulation using GenFlex TPO

Bonding Adhesive applied to both the substrate and the bottom side of the roof

cover for a combined rate of 65 ft²/gal (1.6 m²/L)

Maximum Design

Pressure: -202.5 psf (See General Limitation #9)

MIAMI-DADE COUNTY
APPROVED

NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12 Page 19 of 35

Single Ply, TPO **Membrane Type:**

Deck Type 3I: Concrete, Insulated

Deck Description: Min. 2500 psi structural concrete or concrete plank

System Type A(17): One or more layers of insulation adhered with approved <u>adhesive</u>, membrane

fully adhered

All General and System Limitations apply.

One or more layers of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
ACFoam II, ENRGY 3 Minimum 1.5" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
Structodek High Density Fiberboard Roof Insulation Minimum 0.5" thick	N/A	N/A

Note: All insulation shall be adhered to the deck in ½" to ¾" wide beads 12" o.c. of Millennium One Step Foamable Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: GenFlex TPO or GenFlex TPO Plus, adhered to insulation using GenFlex TPO

Bonding Adhesive applied to both the substrate and the bottom side of the roof

cover for a combined rate of 65 ft²/gal (1.6 m²/L)

Maximum Design

Pressure:

-127.5 psf (See General Limitation #9)



NOA No.: 11-0330.18 **Expiration Date: 07/17/13** Approval Date: 06/14/12

Page 20 of 35

Deck Type 3I: Concrete, Insulated

Deck Description: Min. 2500 psi structural concrete or concrete plank

System Type A(18): One or more layers of insulation adhered with approved <u>adhesive</u>, membrane

fully adhered

All General and System Limitations apply.

One or more layers of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	<u>Fastener</u> Density/ft ²
Approved EPS Insulation Boards Minimum 1.5" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	<u>Fastener</u> <u>Density/ft²</u>
Structodek High Density Fiberboard Roof Insulation Minimum 0.5" thick	N/A	N/A
DensDeck, DensDeck Prime Minimum 0.25" thick	N/A	N/A

Note: All insulation shall be adhered to the deck in ½" to ¾" wide beads 12" o.c. of Millennium One Step Foamable Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: GenFlex TPO or GenFlex TPO Plus, adhered to insulation using GenFlex TPO

Bonding Adhesive applied to both the substrate and the bottom side of the roof

cover for a combined rate of 65 ft²/gal (1.6 m²/L)

Maximum Design
Pressure:
-150 psf (with Structodek) (See General Limitation #9)
-202.5 psf (with DensDeck) (See General Limitation #9)



NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12

Page 21 of 35

Deck Type 3I: Concrete, Insulated

Deck Description: Min. 2500 psi structural concrete or concrete plank

System Type A(19): One or more layers of insulation adhered with approved <u>adhesive</u>, membrane

fully adhered

All General and System Limitations apply.

One or more layers of the following insulations:

Base Insulation Layer	Insulation Fasteners	Fastener
	<u>(Table 3)</u>	Density/ft ²
Approved XPS Insulation Boards		
Minimum 1.0" thick	N/A	N/A

Top Insulation Layer	Insulation Fasteners (Table 3)	<u>Fastener</u> Density/ft ²
Structodek High Density Fiberboard Roof Insulation Minimum 0.5" thick	N/A	N/A
DensDeck, DensDeck Prime Minimum 0.25" thick	N/A	N/A

Note: All insulation shall be adhered to the deck in ½" to ¾" wide beads 12" o.c. of Millennium One Step Foamable Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: GenFlex TPO or GenFlex TPO Plus, adhered to insulation using GenFlex TPO

Bonding Adhesive applied to both the substrate and the bottom side of the roof

cover for a combined rate of 65 ft²/gal (1.6 m²/L)

Maximum Design -172.5 psf (with Structodek) (See General Limitation #9)
-202.5 psf (with DensDeck) (See General Limitation #9)



NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12 Page 22 of 35

Deck Type 3I: Concrete, Insulated

Deck Description: Min. 2500 psi structural concrete or concrete plank

System Type A(20): One or more layers of insulation adhered with approved <u>adhesive</u>, membrane

fully adhered

All General and System Limitations apply.

One or more layers of the following insulations:

Insulation Layer	<u>Insulation Fasteners</u> (Table 3)	<u>Fastener</u> Density/ft ²
ACFoam II, Multi-Max-3, ENRGY 3, H-Shield Minimum 1.5" thick	N/A	N/A
DensDeck, DensDeck Prime Minimum 0 25" thick	N/A	N/A

Note: All insulation shall be adhered to the deck in ½" to ¾" wide beads 12" o.c. of Millennium One Step Foamable Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Vapor Retarders: (Optional) Any UL or FM approved asphaltic vapor retarder may be installed

over the deck or the base layer of insulation

Membrane: GenFlex TPO or GenFlex TPO Plus, adhered to insulation using GenFlex TPO

Bonding Adhesive applied to both the substrate and the bottom side of the roof

cover for a combined rate of 65 ft²/gal (1.6 m²/L)

Maximum Design -202.5 psf (with no vapor retarder) (See General Limitation #9)

Pressure: -157.5 psf (with asphaltic vapor retarder) (See General Limitation #9)



NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12 Page 23 of 35

Deck Type 3I: Concrete, Insulated

Deck Description: Min. 2500 psi structural concrete or concrete plank

System Type A(21): One or more layers of insulation adhered with approved <u>adhesive</u>, membrane

fully adhered

All General and System Limitations apply.

One or more layers of the following insulations:

Base Insulation Layer	Insulation Fasteners	<u> Fastener</u>
	<u>(Table 3)</u>	Density/ft ²
ACFoam II, Multi-Max-3, ENRGY 3, H-Shield, ISO 95+GL		
Minimum 1.5" thick	N/A	N/A
	T 14 F 4	TC 4

Top Insulation Layer Insulation Fasteners (Table 3) Fastener Density/ft²

Structodek High Density Fiberboard roof Insulation

Minimum 0.5" thick N/A N/A

Note: All insulation shall be adhered to the deck in ½" to ¾" wide beads 12" o.c. of Millennium One Step Foamable Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Vapor Retarders: (Optional) Any UL or FM approved asphaltic vapor retarder may be installed

over the deck or the base layer of insulation

Membrane: GenFlex TPO or GenFlex TPO Plus, adhered to insulation using GenFlex TPO

Bonding Adhesive applied to both the substrate and the bottom side of the roof

cover for a combined rate of 65 ft²/gal (1.6 m²/L)

Maximum Design

Pressure: -127.5 psf (See General Limitation #9)

MIAMI-DADE COUNTY
APPROVED

NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12

Page 24 of 35

Deck Type 3I: Concrete, Insulated

Deck Description: Min. 2500 psi structural concrete or concrete plank

System Type A(22): One or more layers of insulation adhered with approved <u>adhesive</u>, membrane

fully adhered

All General and System Limitations apply.

One or more layers of the following insulations:

Insulation Base Layer	<u>Insulation Fasteners</u> (Table 3)	<u>Fastener</u> <u>Density/ft²</u>
ACFoam II, Multi-Max-3, ENRGY 3, H-Shield Minimum 1.5" thick	N/A	N/A
Insulation Top Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
DensDeck, DensDeck Prime Minimum 0.25" thick	N/A	N/A

Note: All insulation shall be adhered to the deck in ½" to ¾" wide beads 12" o.c. of Millennium One Step Foamable Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Vapor Retarders: (Optional) Any UL or FM approved asphaltic vapor retarder may be installed

over the deck or the base layer of insulation

Membrane: GenFlex TPO or GenFlex TPO Plus, adhered to insulation using GenFlex TPO

Bonding Adhesive applied to both the substrate and the bottom side of the roof

cover for a combined rate of 65 ft²/gal (1.6 m²/L)

Maximum Design

Pressure: -135 psf (See General Limitation #9)



NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12

Page 25 of 35

Deck Type 3I: Concrete, Insulated

Deck Description: Min. 2500 psi structural concrete or concrete plank

System Type A(23): One or more layers of insulation adhered with approved <u>adhesive</u>, membrane

fully adhered

All General and System Limitations apply.

One or more layers of the following insulations:

Insulation Layer	Fastener Density/ft ²	Fastener Type
ACFoam II, ACFoam III, ISO 95+GL, Multi-Max FA-3		
Minimum 1.5" thick	N/A	N/A
DensDeck, DensDeck Prime		
Minimum 0.5" thick	N/A	N/A

Note: All insulation shall be adhered to the deck in 3"-3.5" wide ribbons of TITESET Roofing Adhesive, 3M Polyurethane Foam Insulation Adhesive CR-20, spaced 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: GenFlex TPO or GenFlex TPO Plus, adhered to insulation using GenFlex TPO

Bonding Adhesive applied to both the substrate and the bottom side of the roof

cover for a combined rate of 65 ft²/gal $(1.6 \text{ m}^2/\text{L})$

Maximum Design

Pressure: -202.5 psf (See General Limitation #9)



NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12

Page 26 of 35

Deck Type 3I: Concrete, Insulated

Deck Description: Min. 2500 psi structural concrete or concrete plank

System Type A(24): One or more layers of insulation adhered with approved <u>adhesive</u>, membrane

fully adhered

All General and System Limitations apply.

One or more layers of the following insulations:

<u>Insulation Layer</u> <u>Fastener Density/ft²</u> <u>Fastener Type</u>

ACFoam II, ACFoam III, ISO 95+GL

Minimum 1.5" thick N/A N/A

Note: All insulation shall be adhered to the deck in 3"-3.5" wide ribbons of TITESET Roofing Adhesive, 3M Polyurethane Foam Insulation Adhesive CR-20, spaced 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: GenFlex TPO or GenFlex TPO Plus, adhered to insulation using GenFlex TPO

Bonding Adhesive applied to both the substrate and the bottom side of the roof

cover for a combined rate of 65 ft²/gal (1.6 m²/L)

Maximum Design

Pressure: -202.5 psf (See General Limitation #9)

MIAMI-DADE COUNTY
APPROVED

NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12

Page 27 of 35

Deck Type 3I: Concrete, Insulated

Deck Description: Min. 2500 psi structural concrete or concrete plank

System Type A(25): One or more layers of insulation adhered with approved <u>adhesive</u>, membrane

fully adhered

All General and System Limitations apply.

One or more layers of the following insulations:

Base Insulation Layer	Fastener Density/ft ²	Fastener Type
ACFoam II, ACFoam III, ISO 95+GL, Multi-Max FA-3		
Minimum 1.5" thick	N/A	N/A
DensDeck, DensDeck Prime		
Minimum 0.5" thick	N/A	N/A
Top Insulation Layer	Fastener Density/ft ²	Fastener Type
ACFoam II, ACFoam III, ISO 95+GL, Multi-Max FA-3		
Tapered	N/A	N/A

Note: All insulation shall be adhered to the deck in 3"-3.5" wide ribbons of TITESET Roofing Adhesive, 3M Polyurethane Foam Insulation Adhesive CR-20, spaced 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: GenFlex TPO or GenFlex TPO Plus, adhered to insulation using GenFlex TPO

Bonding Adhesive applied to both the substrate and the bottom side of the roof

cover for a combined rate of 65 ft²/gal (1.6 m²/L)

Maximum Design

Pressure: -45 psf (See General Limitation #9)



NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12 Page 28 of 35

Deck Type 3I Concrete, Insulated

Deck Description Min. 2,500 psi structural concrete

System Type C(1): Membrane fully adhered over mechanically fastened insulation.

All General and System Limitations apply.

<u>Insulation for Base Layer (Optional)</u> <u>Fastener Density ft²</u> <u>Fastener Type</u>

GenFlex ISO 3 (flat or tapered), ACFoam II (flat or tapered)

Minimum: 1.3" thick N/A N/A

ACFoam Composite (flat or tapered), Multi-Max FA-3, Thermaroof Composite-3

Minimum: 1.5" thick N/A

Approved High Density Fiberboard, Structodek High Density Fiberboard Roof Insulation

Minimum: ½" thick N/A N/A

Insulation Top Layer	Fastener Density ft ²	<u>Fastener Type</u>
GenFlex ISO 3 or ACFoam II		
Minimum: 1.5" thick	1:2	See approved fasteners in table 3
Minimum: 2.0" thick	1:4	See approved fasteners in table 3
DensDeck, DensDeck Prime		
Minimum: 1/4" thick	1:1.8	See approved fasteners in table 3

Note: All layers shall be simultaneously fastened; see top or base layer for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: GenFlex TPO or GenFlex TPO Plus, adhered to insulation using GenFlex TPO

Bonding Adhesive applied at 30 ft²/gal (0.7 m²/L) to both the substrate and the

bottom side of the roof cover for a combined rate of 60 ft²/gal (1.5 m²/L)

Maximum Design

Pressure: -45 psf; (See General Limitation #9)



NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12 Page 29 of 35

Deck Type 3I: Concrete, Insulated

Deck Description: Min. 2500 psi structural concrete or concrete plank

System Type C(2): Membrane fully adhered over mechanically fastened insulation.

All General and System Limitations apply.

<u>Insulation Base Layer (Optional)</u> <u>Fastener Density ft²</u> <u>Fastener Type</u>

GenFlex ISO 3

Minimum: 1.5" thick N/A

<u>Insulation Top Layer</u> <u>Fastener Density ft²</u> <u>Fastener Type</u>

GenFlex ISO 3

Minimum: 1.5" thick 1:2 GenFast #14 Fasteners with plates

Note: All layers shall be simultaneously fastened; see top or base layer for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: GenFlex TPO Peel & Stick HW, self-adhered to insulation with 3" wide laps

sealed with a minimum 1.5" wide heat weld or primed with GenFlex Clear Primer

and sealed with GenFlex 3" White TPO Seam Tape

Or

GenFlex TPO Peel & Stick SA, self-adhered to insulation with minimum 3" wide

laps. Laps are primed with GenFlex Clear Primer and hand rolled.

Maximum Design

Pressure: -45 psf; (See General Limitation #9)

MIAMI-DADE COUNTY
APPROVED

NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12 Page 30 of 35

Deck Type 3I: Concrete, Insulated

Deck Description: Min. 2500 psi structural concrete or concrete plank

System Type C(3): Membrane fully adhered over mechanically fastened insulation.

All General and System Limitations apply.

<u>Insulation Base Layer</u> <u>Fastener Density ft²</u> <u>Fastener Type</u>

(Optional) Any Approved insulation in Table 2

Minimum: 0.25" thick N/A

<u>Insulation Top Layer</u> <u>Fastener Density ft²</u> <u>Fastener Type</u>

Approved High Density Fiberboard

Minimum: 1.0" thick 1:2 GenFast #14 Fasteners with plates

Note: All layers shall be simultaneously fastened; see top or base layer for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: GenFlex TPO Peel & Stick HW, self-adhered to insulation with 3" wide laps

sealed with a minimum 1.5" wide heat weld or primed with GenFlex Clear Primer

and sealed with GenFlex 3" White TPO Seam Tape

Or

GenFlex TPO Peel & Stick SA, self-adhered to insulation with minimum 3" wide

laps, primed with GenFlex Clear Primer and hand rolled.

Maximum Design

Pressure: -45 psf; (See General Limitation #9)

MIAMI-DADE COUNTY
APPROVED

NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12 Page 31 of 35

Deck Type 3I: Concrete, Insulated

Deck Description: Min. 2500 psi structural concrete or concrete plank

System Type C(4): Membrane fully adhered over mechanically fastened insulation.

All General and System Limitations apply.

One of the following insulations.

<u>Insulation Bottom Layer</u> Fastener Density ft² Fastener Type

Any approved insulation in Table 2

Minimum: 0.25" thick N/A N/A

Insulation Top Layer Fastener Density ft² Fastener Type

GenFlex ISO 3, ACFoam II

Minimum: 1.5" thick 1:1.78 GenFast #14 Fasteners, GenFast 3" Round Insulation Plates

GenFlex ISO 3, ACFoam II

Minimum: 2.0" thick 1:1.78 GenFast #14 Fasteners, GenFast 3" Round Insulation Plates

Note: All layers shall be simultaneously fastened; see top or base layer for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: GenFlex TPO or GenFlex TPO Plus, adhered to insulation using GenFlex TPO

Bonding Adhesive applied to both the substrate and the bottom side of the roof

cover for a combined rate of 65 ft 2 /gal (1.6 m 2 /L).

Maximum Design
Pressure:

-52.5 psf; {for 1.5" insulation} (See General Limitation #7)

-60 psf; {for 2" insulation} (See General Limitation #7)



NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12

Page 32 of 35

Deck Type 3I: Concrete, Insulated

Deck Description: Min. 2500 psi structural concrete or concrete plank

System Type C(5): Membrane fully adhered over mechanically fastened insulation.

All General and System Limitations apply.

<u>Insulation Base Layer</u> <u>Fastener Density ft²</u> <u>Fastener Type</u>

Any approved insulation in Table 2

Minimum: 0.25" thick N/A

<u>Insulation Top Layer</u> <u>Fastener Density ft²</u> <u>Fastener Type</u>

ACFoam III

Minimum: 2" thick 1:1.79 GenFast #14 Fasteners with plates

Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: GenFlex TPO Peel & Stick HW, self-adhered to insulation with 3" wide laps

sealed with a minimum 1.5" wide heat weld or primed with GenFlex Clear Primer

and sealed with GenFlex 3" White TPO Seam Tape

Or

GenFlex TPO Peel & Stick SA, self adhered to insulation with minimum 3" wide

laps. Laps are primed with GenFlex Clear Primer and hand rolled.

Maximum Design

Pressure: -67.5 psf; (See General Limitation #7)



NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12 Page 33 of 35

Deck Type 3I Concrete, Insulated,

Deck Description Min. 2,500 psi structural concrete

System Type D: Membrane attached over preliminary fastened insulation

All General and System Limitations apply.

<u>Insulation for Layer</u> <u>Fastener Density ft²</u> <u>Fastener Type</u>

GenFlex ISO 3 (flat or tapered), ACFoam II (flat or tapered)

Minimum: 1.3" thick N/A

ACFoam Composite (flat or tapered), Multi-Max FA-3, Thermaroof Composite-3

Minimum: 1.5" thick N/A

Approved High Density Fiberboard, Structodek High Density Fiberboard Roof Insulation

Minimum: ½" thick N/A N/A

Note: All insulation shall have preliminary attachment prior to installation of the roofing membrane at a minimum application of two fasteners per board for insulation boards having no dimension greater than 4 ft, and four fasteners for any insulation having no dimension greater than 8 ft.

Membrane: GenFlex TPO or GenFlex TPO Plus, attached to deck as follows. A ⁷/_{32 in} (5.6

mm) diameter pilot hole is drilled in the deck to provide for minimum 1 in. (25 mm) deep fastener embedment. The pilot hole must be 0.5 in (13 mm) deeper

than the embedded fastener.

Fastening #1: GenFast #15 (WH) Fasteners and GenFast Polymer Batten Strip. Screws are

spaced at maximum 12 in (305 mm) o.c. within minimum 4.5 in (114 mm) wide laps, which are spaced at maximum 144 in (3,658 mm) o.c. and sealed with a minimum 1.25 in (32 mm) wide heat weld placed on each side of the batten strip.

Maximum Design: -45 psf.

Fastening #2: GenFast #15 (WH) Fasteners and GenFast Polymer Batten Strip. Screws are

spaced at maximum 6 in (152 mm) o.c. within minimum 5 in (127 mm) wide laps, which are spaced at maximum 144 in (3,658 mm) o.c. and sealed with a minimum 1.5 in (40 mm) wide heat weld placed on the outside edge of the batten strip.

Maximum Design Pressure: -60 psf.

Maximum Design

Pressure: See membrane fastening options above. (See General Limitation #7)



NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12 Page 34 of 35

CONCRETE DECK SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117 and/or RAS 137, calculations shall be signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant.

GENERAL LIMITATIONS:

- 1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
- 2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer.
- 3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
- 4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.

Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.

- 5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
- 6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
- 7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117 and/or RAS 137. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant (When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)
- 8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
- 9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). (When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)
- 10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9N-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE

MIAMI-DADE COUNTY
APPROVED

NOA No.: 11-0330.18 Expiration Date: 07/17/13 Approval Date: 06/14/12 Page 35 of 35